

## Odsey Water Quality Zone (Z8)

## Schedule 1 Parameters

	Units	PCV	Number of samples	Number of Samples contravening PCV	% No. of samples contravening PCV	Minimum	Mean	Maximum
Colour	mg/l Pt/Co	20	5	0	0	<1.70	<1.70	1
Turbidity	FTU	1	5	0	0	0.1	0.1	0.1
Odour	Dil Number	0	5	0	0	0	0	0
Taste	Dil Number	0	5	0	0	0	0	0
Sodium	mg/l	200	3	0	0	12	12.93	14.8
Nitrate (as NO3)	mg/l	50	3	0	0	40.8	41.1	41.6
Nitrite (as NO2)	mg/l	0.1	4	0	0	<0.01	<0.01	<0.01
Nitrate/Nitrite Ratio	mg/l	1	3	0	0	0.82	0.82	0.83
Aluminium	ug/l	-	3	0	0	5	5	5
Iron	ug/l	200	3	0	0	<4.00	4.6333	5.8
Manganese	ug/l	50	3	0	0	0.9	0.9	0.9
Copper	mg/l	2	3	0	0	0.004	0.035	0.072
Fluoride	ug/l	1500	3	0	0	0.14	0.15	0.16
Arsenic	ug/l	10	3	0	0	0.5	0.5	0.5
Cadmium	ug/l	5	3	0	0	<0.10	<0.10	0.06
Chromium	ug/l	50	3	0	0	<0.70	<0.70	0.35
Nickel	ug/l	20	3	0	0	1	1.37	2
Lead	ug/l	10	3	0	0	0.5	0.73	1.1
Antimony	ug/l	5	3	0	0	<0.10	<0.10	0.1
Selenium	ug/l	10	3	0	0	0.5	0.97	1.7
PAH	ug/l	0.1	4	0	0	0	0	0
Escherichia coli	No./100ml	0	17	0	0	0	0	0
Intestinal Enterococci	cfu/100ml	0	3	0	0	0	0	0
Boron	mg/l	1	3	0	0	0.05	0.05	0.05
Benzo(a)pyrene	ug/l	0.01	4	0	0	<0.002	<0.002	<0.002
Trihalomethanes (total)	ug/l	100	4	0	0	5.1	5.8	6.3
Bromate	ug/l	10	1	0	0	<0.50	<0.50	0.4

## Indicator Parameters

	Units	PCV	Number of samples	Number of Samples contravening PCV	% No. of samples contravening PCV	Minimum	Mean	Maximum
pH		-	5	0	0	7.3	7.38	7.5
Sulphate (as SO4)	mg/l	250	3	0	0	39.5	44.33	47.6
Ammonium (as NH4)	mg/l	0.5	5	0	0	0.04	0.04	0.04
Total coliforms	No./100ml	0	17	1	5.88	0	0.0588	1
Clostridium perfringens	No./100ml	0	1	0	0	0	0	0
Free chlorine	mg/l	-	17	0	0	0.03	0.06	0.16
Conductivity	uS/cm	2500	5	0	0	546	600.6	674
Chloride	mg/l	250	3	0	0	39	48	65

\* With the exception of the Total coliform parameter all of the samples collected from this zone in 2018 complied with the Water Supply (Water Quality) (Amendment) Regulations 2018. The unsatisfactory sample was resampled and was found to comply with the regulations.