



Schedule 1 Parameters

Number of

[illegible]

Number of

	Units	PCV	Number of samples	Number of Samples contravening PCV	% No. of samples contravening PCV	Minimum	Mean	Maximum
pH (New Reg Limit) Env		-	2	0	0	7.50	7.55	7.60
Sulphate (as SO4)	mg/l	250	1	0	0	31.60	31.60	31.60
Ammonium (as NH4)	mg/l	0.5	2	0	0	<0.02	0.02	0.02
Total coliforms	No./100ml	0	5	0	0	0.00	0.00	0.00
Clostridium perfringens	No./100ml	0	1	0	0	0.00	0.00	0.00
3 day count,22 deg C	cfu/ml	50	2	0	0	0.00	0.00	0.00
Free chlorine	mg/l	-	5	0	0	0.05	0.07	0.09
Conductivity	uS/cm	2500	2	0	0	613.00	638.50	664.00
Chloride	mg/l	250	1	0	0	72.00	72.00	72.00

* All of the samples collected from this zone in 2024 complied with the Water Supply (Water Quality) (Amendment) Regulations 2016.